

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of June 09, 2026***2012-00004**

RECEIVED: 12/05/11

FILED: 12/05/11

FINAL: 03/02/12

REOPENED:

SUSPENSION DATE:

CASE NATURE: Request to Extend Rural Water Main in Excess of Permitted Lengths

CASE CODE

Deviation

UTILITIES:

Bath County Water District

INDEX OF EVENTS:

03/08/12 Order Entered: 1. Bath District's request for deviation from 807 KAR 5066, Section 10(2)(a) is granted. 2. Bath District is permitted to place into service the proposed 2-inch PVC water main of 4,585 linear feet to run along Starshader Lane in Bath County, Kentucky. 3. Bath District shall continue to use the proposed water main only as long as the water main complies with all other sections of 807 KAR 5066. 4. Bath District shall monitor the adequacy of the proposed water main and shall take necessary actions to maintain the level of service within the standards set forth in 807 KAR 5:066. 5. Bath District shall provide service on this main or any other water main to any customer who is entitled to service under the Commission's regulations and Bath District's filed rate schedules and regulations provided, however, appropriate engineering studies are performed and the approval of the Kentucky Division of Water and the Commission is obtained.

02/24/12 Letter to Kenny Barber Filing Documents into the Record

01/05/12 Acknowledge Receipt of Filing

12/05/11 Request of Bath County Water District Under the Provisions of 807 KAR 5:066, Section 10, For Authorization to Extend a Rural Water Main In Excess of Permitted Lengths

Total Number of Cases: 1